




Teleskopska klizna grla hoda 300 mm




Detalj B
Mjerilo 1:5


Regulacija kliznih
grla vijcima M12x25




AB podloga



Čelični anker



koalescentni
uložak
Kontrola
opterećenosti



Polipropilenski
koalescentni
uložak

Separatori spadaju u I. klasu
separatora prema hrvatskoj normi
HRN EN 858 što znači da je količina
rezidualnog ulja manja od 5 mg/l

Volumen separatora: 15000 l
Protok separatora: 60 l/s
Cijevi: Ø315
Masa praznog separatora: 2350 kg
Masa punog separatora: 15500 kg

Površina	Mjerilo	1:50	Pozicija	-	Masa	-
		EN 858				

Ime		Datum	Podpis	
Čiao	Levačić I. dđrling, str.			
Priekontl	Horvat D.maging, međh.			
Odobrio	Horvat Dj. str./teh. sec.			
Separator 15000				
Q=60 lit/sec				

Tehnix

TX-DK-D-1907-SEP-15000-S1

rad/bil. Promjena Datum Ime Spremljeno TX-DK-D-1907-SEP-15000-S1 Page Pg

